



**DEPARTMENT of AGRICULTURE
and NATURAL RESOURCES**

221 MALL DRIVE, SUITE #201
RAPID CITY SD 57701
danr.sd.gov

November 18, 2024

Mr. Forrest Zuber
Spring Creek Sanitary District
PO Box 623
Pierre, SD 57501

RE: Spring Creek Sanitary District Public Water System (EPA ID 2089)

Dear Mr. Zuber:

The Drinking Water Program has received results of your Stage 2 Disinfection By-Products (DBP) sample dated September 12, 2024. Your water system is in compliance for THMs/HAA5s. The regulations require that results of the compliance monitoring be kept on file for at least ten years.

Surface water systems with a population of less than 500 are not eligible to reduce below sampling once per year, so your system will remain on routine monitoring frequency. The system is required to sample annually at the approved sampling location. The next sample is due between **August 1 and September 30, 2025.**

Thank you for your interest in keeping a safe water supply for your community. If there are any questions on this matter, please contact me.

Sincerely,

Erin Fagnan
Drinking Water Program
(605) 910-4953